

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. -26

Dated: 27-05-2025

It is certified that an inspection team headed by D.N. Joshi

(Name of Officers with designation) from U.S.S. Bageshwar PHED

inspected the P.M. Shri A.V.G.I.C. Amsyari, P.O. Bhilkot, Dis. Bageshwar

(Name & Address of the school) on 24-05-25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 26/USS/DLWQATML/25-26 dated 26-05-2025

of UTTARAKHAND TAL SANSTHAN (PHED Lab) certified that the

P.M. Shri A.V.G.I.C. Amsyari (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till

Signature with Seal: [Signature]

Name D.N. Joshi

Designation Chemist

Name & Address of the Office / Department

Distt Water Quality Testing Monitoring

Laboratory

Uttarakhand Tal Sansthan, Bageshwar

To P.M. Shri A.V.G.I.C. Amsyari
P.O. Bhilkot, Dis. Bageshwar
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



District Level Water Quality Testing and Monitoring Laboratory

Uttarakhand Jal Sansthan, Bageshwar

Ph (OFFICE): 05963-220038, E-mail: ceujsbgr@gmail.com

TEST REPORT

Name and Address of Organization/ Customer	PM Shri Atal Utkrisht GIC Amsyari, Bageshwar		
Test Report ID	26-B/UJS/DLWQTML/2025-26	Reporting Date	27-05-2025
ULR No.	TC13234250000000026F	Sample Location	GIC Amsyari
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/AA-01		
Date of Start of Analysis:	24-05-2025		
Date of End of Analysis:	26-05-2025		
Date and Time of Sample Received:	24-05-2025 10:45AM		

Bacteriological Parameters

SN	Water Quality Parameters Under Biological Scope	Results	Desirable Limit (BIS)	Permissible Limit(BIS) In the Absence of alternative source	Std. Test Method
1	Total Coliform, MPN/100ML	Absent	Absent	Absent	APHA 23rd Ed.-9223 B
2	E- Coli , MPN/100ML	Absent	Absent	Absent	APHA 23rd Ed.-9223.B



-End of Report-

... of testing